

PANEL BOARD CODE LP1										BRANCE CB (IC) 5 KA @ 220 V.										
CAPACITY 24										MOUNTING SURFACE										
TYPE : 3 PHASE 4 WIRES S/N 240415 Vw										LOCATION 1st FLOOR										
LOAD IN VA										LOAD IN VA										
DESCRIPTION	PHASE R	PHASE S	PHASE T	CONDUCTOR EMT	CONDUCTOR SIZE (sqmm) TYPE-TW	BRANCH CB ATAFIP	NO.	DIAGRAM	NO.	BRANCH CB ATAFIP	CONDUCTOR SIZE (sqmm) TYPE-TW	CONDUCTOR EMT	PHASE R	PHASE S	PHASE T	DESCRIPTION				
LIGHTING	780			1/2"	2x2.5, 1x2.5	15K31	1		2	15K31	2x2.5, 1x2.5	1/2"	1000			RECEPTACLE				
LIGHTING		1360		1/2"	2x2.5	10K31	3		4	15K31	2x2.5, 1x2.5	1/2"	1000			1000	RECEPTACLE			
LIGHTING			300	1/2"	2x2.5	10K31	5		6	15K31	2x2.5, 1x2.5	1/2"	1000			1000	RECEPTACLE			
LIGHTING	1200			1/2"	2x2.5	10K31	7		8	15K31	2x2.5, 1x2.5	1/2"	1000			1000	RECEPTACLE			
LIGHTING		1200		1/2"	2x2.5	10K31	9		10	15K31	2x2.5, 1x2.5	1/2"	1000			1000	RECEPTACLE			
LIGHTING			1600	1/2"	2x2.5	10K31	11		12	15K31	2x2.5, 1x2.5	1/2"	1000			1200	SPARE			
LIGHTING	1400			1/2"	2x2.5	10K31	13		14	15K31	2x2.5, 1x2.5	1/2"	300			300	FCP			
LIGHTING		1620		1/2"	2x2.5	10K31	15		16	15K31	-	-	-			1000	SPARE			
RECEPTACLE		1440		1/2"	2x2.5, 1x2.5	15K31	17		18	15K31	-	-	-			1000	SPARE			
RECEPTACLE	1440			1/2"	2x2.5, 1x2.5	15K31	19		20	15K31	-	-	-			1200	SPARE			
RECEPTACLE		1080		1/2"	2x2.5, 1x2.5	15K31	21		22	15K31	-	-	-			1080	SPARE			
RECEPTACLE			1500	1/2"	2x2.5, 1x2.5	15K31	23		24	15K31	-	-	-			1080	SPARE			
TOTAL LOAD/PHASE (VA)										PHASE R S T										
										4320 3600 4320										
CONNECTED LOAD 27.10 KVA										MAIN CB 60AT100AF 3P										
DEMAND LOAD 21.68 KVA										(IC) 15 KA CURRENT/PHASE 32.95 AMP.										
										WIRE SIZE 4x16, 1x6 Sqmm, TW in 1 1/4" EMT.										

PANEL BOARD CODE LP2										BRANCE CB (IC) 5 KA @ 220 V.										
CAPACITY 24										MOUNTING SURFACE										
TYPE : 3 PHASE 4 WIRES S/N 240415 Vw										LOCATION 2nd FLOOR										
LOAD IN VA										LOAD IN VA										
DESCRIPTION	PHASE R	PHASE S	PHASE T	CONDUCTOR EMT	CONDUCTOR SIZE (sqmm) TYPE-TW	BRANCH CB ATAFIP	NO.	DIAGRAM	NO.	BRANCH CB ATAFIP	CONDUCTOR SIZE (sqmm) TYPE-TW	CONDUCTOR EMT	PHASE R	PHASE S	PHASE T	DESCRIPTION				
LIGHTING	1720			1/2"	2x2.5, 1x2.5	10K31	1		2	15K31	2x2.5, 1x2.5	1/2"	1520			1720	RECEPTACLE			
LIGHTING		1380		1/2"	2x2.5	10K31	3		4	15K31	2x2.5, 1x2.5	1/2"	1720			1720	RECEPTACLE			
LIGHTING			1380	1/2"	2x2.5	10K31	5		6	15K31	2x2.5, 1x2.5	1/2"	1720			1320	RECEPTACLE			
LIGHTING	1800			1/2"	2x2.5	10K31	7		8	15K31	2x2.5, 1x2.5	1/2"	1440			1440	RECEPTACLE			
LIGHTING		1200		1/2"	2x2.5	10K31	9		10	15K31	2x2.5, 1x2.5	1/2"	1440			1440	RECEPTACLE			
LIGHTING			1380	1/2"	2x2.5	10K31	11		12	15K31	2x2.5, 1x2.5	1/2"	1700			1700	RECEPTACLE			
LIGHTING	1380			1/2"	2x2.5	10K31	13		14	15K31	-	-	-			1000	SPARE			
LIGHTING		1380		1/2"	2x2.5	10K31	15		16	15K31	-	-	-			1000	SPARE			
LIGHTING			1660	1/2"	2x2.5	15K31	17		18	15K31	-	-	-			1000	SPARE			
RECEPTACLE	1080			1/2"	2x2.5, 1x2.5	15K31	19		20	15K31	-	-	-			1080	SPARE			
RECEPTACLE		1440		1/2"	2x2.5, 1x2.5	15K31	21		22	15K31	-	-	-			1080	SPARE			
RECEPTACLE			1080	1/2"	2x2.5, 1x2.5	15K31	23		24	15K31	-	-	-			1080	SPARE			
TOTAL LOAD/PHASE (VA)										PHASE R S T										
										1660 1080 1080										
CONNECTED LOAD 32.26 KVA										MAIN CB 60AT100AF 3P										
DEMAND LOAD 25.89 KVA										(IC) 15 KA CURRENT/PHASE 33.34 AMP.										
										WIRE SIZE 4x16, 1x6 Sqmm, TW in 1 1/4" EMT.										


PANEL BOARD CODE LP3										BRANCE CB (IC) 5 KA @ 220 V.										
CAPACITY 24										MOUNTING SURFACE										
TYPE : 3 PHASE 4 WIRES S/N 240415 Vw										LOCATION 3rd FLOOR										
LOAD IN VA										LOAD IN VA										
DESCRIPTION	PHASE R	PHASE S	PHASE T	CONDUCTOR EMT	CONDUCTOR SIZE (sqmm) TYPE-TW	BRANCH CB ATAFIP	NO.	DIAGRAM	NO.	BRANCH CB ATAFIP	CONDUCTOR SIZE (sqmm) TYPE-TW	CONDUCTOR EMT	PHASE R	PHASE S	PHASE T	DESCRIPTION				
LIGHTING/AREC	1160			1/2"	2x2.5, 1x2.5	15K31	1		2	15K31	2x2.5, 1x2.5	1/2"	1160			1160	LIGHTING/AREC			
LIGHTING/AREC		1160		1/2"	2x2.5, 1x2.5	15K31	3		4	15K31	2x2.5, 1x2.5	1/2"	1160			1160	LIGHTING/AREC			
LIGHTING/AREC			1160	1/2"	2x2.5, 1x2.5	15K31	5		6	15K31	2x2.5, 1x2.5	1/2"	1160			1160	LIGHTING/AREC			
LIGHTING/AREC	1160			1/2"	2x2.5, 1x2.5	15K31	7		8	15K31	2x2.5, 1x2.5	1/2"	1160			1160	LIGHTING/AREC			
LIGHTING/AREC		1160		1/2"	2x2.5, 1x2.5	15K31	9		10	15K31	2x2.5, 1x2.5	1/2"	1160			1160	LIGHTING/AREC			
LIGHTING/AREC			1160	1/2"	2x2.5, 1x2.5	15K31	11		12	15K31	2x2.5, 1x2.5	1/2"	1000			1000	RECEPTACLE			
LIGHTING/AREC	1160			1/2"	2x2.5, 1x2.5	15K31	13		14	15K31	-	-	-			1000	RECEPTACLE			
LIGHTING/AREC		1160		1/2"	2x2.5, 1x2.5	15K31	15		16	15K31	-	-	-			800	RECEPTACLE			
LIGHTING/AREC			1160	1/2"	2x2.5, 1x2.5	15K31	17		18	15K31	-	-	-			1000	SPARE			
LIGHTING/AREC	1160			1/2"	2x2.5, 1x2.5	15K31	19		20	15K31	-	-	-			1000	SPARE			
LIGHTING/AREC		1160		1/2"	2x2.5, 1x2.5	15K31	21		22	15K31	-	-	-			1000	SPARE			
LIGHTING/AREC			1160	1/2"	2x2.5, 1x2.5	15K31	23		24	15K31	-	-	-			1000	SPARE			
TOTAL LOAD/PHASE (VA)										PHASE R S T										
										1160 1160 1160										
CONNECTED LOAD 29.82 KVA										MAIN CB 60AT100AF 3P										
DEMAND LOAD 21.46 KVA										(IC) 15 KA CURRENT/PHASE 32.61 AMP.										
										WIRE SIZE 4x16, 1x6 Sqmm, TW in 1 1/4" EMT.										

PANEL BOARD CODE LP4										BRANCE CB (IC) 5 KA @ 220 V.										
CAPACITY 30										MOUNTING SURFACE										
TYPE : 3 PHASE 4 WIRES S/N 240415 Vw										LOCATION 2nd FLOOR										
LOAD IN VA										LOAD IN VA										
DESCRIPTION	PHASE R	PHASE S	PHASE T	CONDUCTOR EMT	CONDUCTOR SIZE (sqmm) TYPE-TW	BRANCH CB ATAFIP	NO.	DIAGRAM	NO.	BRANCH CB ATAFIP	CONDUCTOR SIZE (sqmm) TYPE-TW	CONDUCTOR EMT	PHASE R	PHASE S	PHASE T	DESCRIPTION				
AR 4800STU	2040			3/4"	4x2.5, 1x2.5	20K31	1		2	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU		2040		3/4"	4x2.5, 1x2.5	20K31	3		4	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU			2040	3/4"	4x2.5, 1x2.5	20K31	5		6	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU	2040			3/4"	4x2.5, 1x2.5	20K31	7		8	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU		2040		3/4"	4x2.5, 1x2.5	20K31	9		10	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU			2040	3/4"	4x2.5, 1x2.5	20K31	11		12	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU	2040			3/4"	4x2.5, 1x2.5	20K31	13		14	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU		2040		3/4"	4x2.5, 1x2.5	20K31	15		16	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU			2040	3/4"	4x2.5, 1x2.5	20K31	17		18	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU	2040			3/4"	4x2.5, 1x2.5	20K31	19		20	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU		2040		3/4"	4x2.5, 1x2.5	20K31	21		22	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
AR 4800STU			2040	3/4"	4x2.5, 1x2.5	20K31	23		24	20K31	4x2.5, 1x2.5	3/4"	2040			2040	AR 4800STU			
SPARE							25		26	20K31	-	-	-				SPARE			
SPARE							27		28	20K31	-	-	-				SPARE			
SPARE							29		30	20K31	-	-	-				SPARE			
TOTAL LOAD/PHASE (VA)										PHASE R S T										
										16320 16320 16320										
CONNECTED LOAD 48.96 KVA										MAIN CB 10AT100AF 3P										
DEMAND LOAD 44.36 KVA										(IC) 15 KA CURRENT/PHASE 74.41 AMP.										
										WIRE SIZE 4x50, 1x10 Sqmm, TW in 2" EMT.										

การอนุมัติ
 อนุมัติให้ดำเนินการ
 1. 10309
 2. 10309
 3. 10309


LOAD SCHEDULE

10309



แปลนระบบไฟฟ้ากำลัง LAN และโทรศัพท์ชั้นล่าง
 1:100

โครงการ อาคารศูนย์บริการลูกค้า ชั้นล่าง	
แบบ 10309	
1. วิศวกร 2. วิศวกร 3. วิศวกร 4. วิศวกร 5. วิศวกร	1. วิศวกร 2. วิศวกร 3. วิศวกร 4. วิศวกร 5. วิศวกร
10309	
10309	
10309	



FLOOR	CODE "N"
3	3
4	4
5	5
6	6
7	7

แปลระบอบสถาปัตย์จากผังแปลนใหม่ชั้นที่ 3-7
 1:100

กองแบบแปลน
 กรมโยธาธิการและผังเมือง
 กรุงเทพมหานคร

แบบ

ขอทำแบบแปลน
 แปลนอาคาร
 ชั้น 3-7

1. ฐานราก
 2. เสา
 3. คาน
 4. ผนัง
 5. ประตู
 6. หน้าต่าง
 7. เสาเข็ม
 8. เสาเข็มตอก
 9. เสาเข็มเจาะ
 10. เสาเข็มเจาะ
 11. เสาเข็มเจาะ
 12. เสาเข็มเจาะ
 13. เสาเข็มเจาะ
 14. เสาเข็มเจาะ
 15. เสาเข็มเจาะ
 16. เสาเข็มเจาะ
 17. เสาเข็มเจาะ
 18. เสาเข็มเจาะ
 19. เสาเข็มเจาะ
 20. เสาเข็มเจาะ
 21. เสาเข็มเจาะ
 22. เสาเข็มเจาะ
 23. เสาเข็มเจาะ
 24. เสาเข็มเจาะ
 25. เสาเข็มเจาะ
 26. เสาเข็มเจาะ
 27. เสาเข็มเจาะ
 28. เสาเข็มเจาะ
 29. เสาเข็มเจาะ
 30. เสาเข็มเจาะ
 31. เสาเข็มเจาะ
 32. เสาเข็มเจาะ
 33. เสาเข็มเจาะ
 34. เสาเข็มเจาะ
 35. เสาเข็มเจาะ
 36. เสาเข็มเจาะ
 37. เสาเข็มเจาะ
 38. เสาเข็มเจาะ
 39. เสาเข็มเจาะ
 40. เสาเข็มเจาะ
 41. เสาเข็มเจาะ
 42. เสาเข็มเจาะ
 43. เสาเข็มเจาะ
 44. เสาเข็มเจาะ
 45. เสาเข็มเจาะ
 46. เสาเข็มเจาะ
 47. เสาเข็มเจาะ
 48. เสาเข็มเจาะ
 49. เสาเข็มเจาะ
 50. เสาเข็มเจาะ
 51. เสาเข็มเจาะ
 52. เสาเข็มเจาะ
 53. เสาเข็มเจาะ
 54. เสาเข็มเจาะ
 55. เสาเข็มเจาะ
 56. เสาเข็มเจาะ
 57. เสาเข็มเจาะ
 58. เสาเข็มเจาะ
 59. เสาเข็มเจาะ
 60. เสาเข็มเจาะ
 61. เสาเข็มเจาะ
 62. เสาเข็มเจาะ
 63. เสาเข็มเจาะ
 64. เสาเข็มเจาะ
 65. เสาเข็มเจาะ
 66. เสาเข็มเจาะ
 67. เสาเข็มเจาะ
 68. เสาเข็มเจาะ
 69. เสาเข็มเจาะ
 70. เสาเข็มเจาะ
 71. เสาเข็มเจาะ
 72. เสาเข็มเจาะ
 73. เสาเข็มเจาะ
 74. เสาเข็มเจาะ
 75. เสาเข็มเจาะ
 76. เสาเข็มเจาะ
 77. เสาเข็มเจาะ
 78. เสาเข็มเจาะ
 79. เสาเข็มเจาะ
 80. เสาเข็มเจาะ
 81. เสาเข็มเจาะ
 82. เสาเข็มเจาะ
 83. เสาเข็มเจาะ
 84. เสาเข็มเจาะ
 85. เสาเข็มเจาะ
 86. เสาเข็มเจาะ
 87. เสาเข็มเจาะ
 88. เสาเข็มเจาะ
 89. เสาเข็มเจาะ
 90. เสาเข็มเจาะ
 91. เสาเข็มเจาะ
 92. เสาเข็มเจาะ
 93. เสาเข็มเจาะ
 94. เสาเข็มเจาะ
 95. เสาเข็มเจาะ
 96. เสาเข็มเจาะ
 97. เสาเข็มเจาะ
 98. เสาเข็มเจาะ
 99. เสาเข็มเจาะ
 100. เสาเข็มเจาะ

แปลนอาคารจากผังแปลนใหม่ชั้นที่ 3-7

แบบเลขที่ 10309

วันที่ 10/10/60

ชื่อแบบ

ชื่อผู้จัดทำ

